

**STATE OF ILLINOIS
ILLINOIS COMMERCE COMMISSION**

AMEREN TRANSMISSION COMPANY OF ILLINOIS)	
)	
Petition for a Certificate of Public Convenience and)	
Necessity, pursuant to Section 8-406.1 of the Illinois)	
Public Utilities Act, and an Order pursuant to Section 8-)	Docket No. 12-0598
503 of the Public Utilities Act, to Construct, Operate and)	
Maintain a New High Voltage Electric Service Line and)	
Related Facilities in the Counties of Adams, Brown,)	
Cass, Champaign, Christian, Clark, Coles, Edgar, Fulton,)	
Macon, Montgomery, Morgan, Moultrie, Pike,)	
Sangamon, Schuyler, Scott and Shelby, Illinois.)	

REHEARING ERRATA OF AMEREN TRANSMISSION COMPANY OF ILLINOIS

Ameren Transmission Company of Illinois hereby submits the following errata relating to its *Direct and Rebuttal Testimony and Exhibits on Rehearing*, as originally filed with the Illinois Commerce Commission via e-Docket on November 13, 2013 and December 2, 2013, respectively. The changes reflected in this errata are intended to address ministerial, computational or technical corrections required in and/or inadvertent omissions from the Company's Direct and Rebuttal Testimony and Exhibits on Rehearing, as provided for in 83 Ill. Adm. Code Section 200.670(d). Clean copies of the revised documents identified below are being filed contemporaneously with the errata and contain the following corrections:

Direct Testimony on Rehearing:

**ATXI Exhibit 1.0 (RH) (Rev.)—Direct Testimony
on Rehearing of Dennis D. Kramer**

1. On page 6, lines 120-21, "and Kincaid" be deleted and "power plants" be revised to "power plant" so that the full sentence reads, "The Kincaid connection does not provide the same level of increased stability for the Coffeen power plant";
2. On page 7, line 150, replace "provide greater" with "improve" so that the full sentence reads, "How would a Pana connection improve stability at the Coffeen and Kincaid power plants?";

3. Page 8, lines 183-84, delete “compared to the Kincaid connection” so that the full sentence reads, “We determined that the Pana connection improved the stability of the Kincaid power plant by approximately 5%”; and
4. Page 8, line 185, insert a comma after “10%”, replace “connection” with “connection’s” and insert “0% improvement of Coffeen stability” after “connection’s”, so that the full sentence reads, “The Pana connection also improved the stability of the Coffeen power plant by approximately 10%, compared to the Kincaid connection’s 0% improvement of Coffeen stability.”

Rebuttal Testimony and Exhibits on Rehearing:

**ATXI Exhibit 4.0 (RH) (Rev.)—Rebuttal Testimony
on Rehearing of Dennis D. Kramer**

1. On page 10, line 207, delete “on rehearing” so that the full sentence reads, “Locating the Mt. Zion substation at the location proposed by Mr. Rockrohr in his direct testimony would result in 138 kV connections to the Decatur area being approximately 30 miles in length.”

**ATXI Exhibit 5.1 (RH) (Rev.)—Supporting Exhibit
to the Rebuttal Testimony on Rehearing of Jeffrey V. Hackman**

1. On page 2, footnote 1, replace cite to “ATXI Exhibit 16.3 (2d Rev.)” with “ATXI Exhibit 16.3 (Rev.)”.

Dated: December 16, 2013

Respectfully submitted,
Ameren Transmission Company of Illinois

/s/ Albert D. Sturtevant

One of their Attorneys

Edward C. Fitzhenry
Matthew R. Tomc
Eric E. Dearmont
AMEREN SERVICES COMPANY
One Ameren Plaza
1901 Chouteau Avenue
St. Louis, Missouri 63166
(314) 554-3533
(314) 554-4014 (fax)
efitzhenry@ameren.com
mtomc@ameren.com
edearmont@ameren.com

Mark A. Whitt
Shannon K. Rust
WHITT STURTEVANT LLP
88 East Broad Street, Suite 1590
Columbus, Ohio 43215
(614) 224-3911
whitt@whitt-sturtevant.com
rust@whitt-sturtevant.com

Albert D. Sturtevant
Anne M. Zehr
Rebecca L. Segal
Hanna M. Conger
WHITT STURTEVANT LLP
180 N. LaSalle Street, Suite 2001
Chicago, Illinois 60601
(312) 251-3017
sturtevant@whitt-sturtevant.com
zehr@whitt-sturtevant.com
segal@whitt-sturtevant.com
conger@whitt-sturtevant.com

CERTIFICATE OF SERVICE

I, Albert D. Sturtevant, an attorney, certify that December 16, 2013, I caused a copy of the foregoing *Rehearing Errata of Ameren Transmission Company of Illinois* to be served by electronic mail to the individuals on the Commission's Service List for Docket 12-0598.

/s/ Albert D. Sturtevant

Attorney for Ameren Transmission
Company of Illinois